



CENTRAL ELMORE WATER & SEWER AUTHORITY QUALITY INTEGRITY SERVICE			
STANDARD 3/4" OR 1" WATER SERVICE INSTALLATION			
REVISIONS	DATE	REVISIONS	DATE
CS	07/22/15	CS - METER TYPE	04/22/19

- NOTES:
1. WATER METER AS MANUFACTURED BY NEPTUNE R900 PRO -CODER.
 2. DIRECT TAP ALLOWED ON MAINS NO LARGER THAN 16" LINE.
 3. METER BOX TO BE LOCATED UP TO 3 FEET ONTO CUSTOMER'S PROPERTY.
 4. AT THE CUSTOMER'S EXPENSE, THE CUSTOMER IS REQUIRED TO INSTALL AND MAINTAIN THE SERVICE PIPING, PRIVATE CUT-OFF VALVE, AND PRESSURE REGULATOR ON THE CUSTOMER'S SIDE OF THE AUTHORITY'S METER/METER BOX.
 5. THE AUTHORITY SHALL PROVIDE A CUT-OFF VALVE, METER/METER BOX, AND BACKFLOW PREVENTER ON IT'S SIDE OF THE SERVICE CONNECTION.
 6. THE PRESSURE REGULATOR IS THE RESPONSIBILITY OF THE CUSTOMER. THE CUSTOMER'S RESPONSIBILITY INCLUDES MAINTENANCE AND REPLACEMENT AS NEEDED OF THE PRESSURE REGULATOR. THE AUTHORITY WILL NOT BE HELD ACCOUNTABLE AT ANY TIME FOR THE REPLACEMENT COSTS OF PRESSURE REGULATOR, ANY COSTS ASSOCIATED WITH THE LACK OF PRESSURE REGULATOR OR THE FAILURE OF THE REGULATOR.